



P.O. Box 368, St. Walburg, SK S0M 2T0
 (306) 248-3232 • Fax: (306) 248-3484
www.stwalburg.com

Drinking Water Quality and Compliance Town of St. Walburg Annual Notice to Consumers

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the **Town of St. Walburg** water quality and sample submission compliance record for the **January 1 to December 31, 2021** time period. This report was completed on **May 31, 2022**.

Readers should refer to Water Security Agency's [Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502](#) for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, 'what is the significance of Selenium in a water supply', more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html.

Water Quality Standards

Bacteriological Quality

Parameter/Location	Limit	Regular Samples Required	Regular Samples Submitted	# of Positive Regular Submitted (%)
Total Coliform	0 Organisms/100mL	52	52	4%
E. Coli	0 Organisms/100mL	52	52	0%

Water Disinfection - Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests Required	# Tests Submitted	# Adequate Chlorine (%)
Chlorine Residual	0.1 mg/L Free OR 0.5 mg/L Total	0.25 to 0.82	0.12 to 0.63	52	52	100%

A minimum of 0.1 milligrams per litre [mg/L] free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual [highest and lowest recorded values] and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity - From Water Treatment Plant Records

Parameter	Limit [NTU]	Test Level Range	# of Tests Not Meeting Requirements	Maximum Turbidity [NTU]	# Tests Required	# Tests Performed
Turbidity	1.0	0.05 to 0.24	0	0.24	365	365

Chemical - Health Category

All waterworks serving less than 5000 persons are required to submit water samples for SE's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium, and uranium.

The last sample for Chemical Health analysis was submitted on **March 16, 2021**. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	Limit MAC [mg/L]	Limit IMAC [mg/L]	Sample Result[s]	# Samples Exceeding Limit
Arsenic	0.010		0.0037	0
Barium	1.0		0.022	0
Boron		5.0	0.3	0
Cadmium	0.005		<0.00001	0
Chromium	0.050		<0.0005	0
Lead	0.010		0.0001	0
Selenium	0.010		<0.0001	0
Uranium	0.020		0.0005	0

Chemical - Trihalomethanes [THMs]

Parameter	THMs Limit [mg/L]	Sample Result	# Samples Required	# Samples Submitted
Trihalomethanes	0.1	0.0345	1	1

Note: Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor for THMS. Waterworks using groundwater sources beyond the influence of surface water do not need to report THMs since sampling/analysis will not likely have been performed unless otherwise noted in the waterworks permit to operate.

General Chemical

Parameter	Aesthetic Objectives* [mg/L]	Sample Results [average]	# Samples Required	# Samples Submitted
Alkalinity	500	446	1	1
Bicarbonate	No Objective	539	1	1
Calcium	No Objective	81	1	1
Carbonate	No Objective	3	1	1
Chloride	250	45.7	1	1
Conductivity	No Objective	1121	1	1
Hardness	800	330	1	1
Magnesium	200	31	1	1
PH	No Objective	8.1	1	1
Sodium	300	130	1	1
Sulphate	500	106.5	1	1
Total Dissolved Solids	1500	943	1	1

All waterworks serving less than 5000 persons are required to submit water samples for SE's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness [as CaCO₃], magnesium, sodium, sulphate, and total dissolved solids.

The last sample for General Chemical analysis was required in **2021** and submitted on December 6, 2021. Sample results indicated that there were no exceedances of the provincial aesthetic objectives for the General Chemical category.

*Objectives apply to certain characteristics of, or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters [including hardness as CaCO₃, magnesium, sodium, and total dissolved solids] consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

Town of St. Walburg
Shiloh Bronken, Chief Administrative Officer
PO Box 368, St. Walburg, SK S0M 2T0
306-248-3232 or 306-248-3484 [fax]
sbronken@stwalburg.com



Saskatchewan
Ministry of
Environment

